

ПС 35/6 кВ Касево

День	Месяц	Год
20	12	2023

Присоединение	Ед. изм.	Ввод №1 ил. №5 на 1 сек. ш.																									
		00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	
Ввод №1 ил. №5 на 1 сек. ш.	фидер 6 кВ	A	175	164,0	158,0	149,0	143,0	144,0	151,0	157,0	163,0	175,0	180,0	184,0	185,0	190,0	191,0	195,0	195,0	196,0	200,0	205,0	204,0	200,0	194,0	187,0	182,0
	фидер 6 кВ	МВт																									
	фидер 6 кВ	A	42	40,0	39,0	33,0	30,0	30,0	31,0	35,0	40,0	43,0	42,0	43,0	44,0	44,0	46,0	46,0	48,0	48,0	50,0	52,0	50,0	47,0	44,0		
	фидер №9 1 сек. ш.	МВт																									
	фидер 6 кВ	A	52	51,0	50,0	49,0	48,0	48,0	48,0	50,0	53,0	55,0	54,0	53,0	56,0	56,0	57,0	57,0	56,0	55,0	55,0	55,0	53,0	51,0	50,0	49,0	
	фидер №11 1 сек. ш.	МВт																									
	фидер 6 кВ	A	34	30,0	31,0	24,0	24,0	25,0	25,0	27,0	30,0	31,0	32,0	33,0	32,0	31,0	32,0	31,0	32,0	33,0	35,0	35,0	36,0	32,0	30,0		
	фидер №13 1 сек. ш.	МВт																									
	фидер 6 кВ	A	50	49,0	48,0	47,0	45,0	43,0	43,0	44,0	45,0	47,0	52,0	55,0	56,0	58,0	61,0	62,0	61,0	62,0	63,0	64,0	62,0	61,0	60,0	65,0	59,0
	фидер №15 1 сек. ш.	МВт																									
Ввод №2 ил. №14 на 2 сек. ш.	фидер 6 кВ	A	28	27,0	23,0	25,0	25,0	26,0	27,0	27,0	29,0	30,0	30,0	31,0	33,0	31,0	30,0	30,0	31,0	30,0	30,0	30,0	30,0	29,0	28,0	29,0	
	фидер №4 2 сек. ш.	МВт																									
	фидер 6 кВ	A	41	40,0	39,0	43,0	44,0	45,0	46,0	45,0	42,0	45,0	44,0	46,0	53,0	52,0	52,0	50,0	50,0	49,0	45,0	44,0	44,0	41,0	40,0		
	фидер №8 2 сек. ш.	МВт																									
	фидер 6 кВ	A	68	65,0	63,0	71,0	72,0	70,0	73,0	71,0	73,0	73,0	75,0	78,0	85,0	83,0	82,0	83,0	81,0	80,0	76,0	74,0	74,0	73,0	69,0	65,0	
	фидер 6 кВ	МВт																									
Напряж 6 кВ ТТ 1 сек. ш.	кВ	6,10	6,10	6,10	6,20	6,10	6,20	6,10	6,10	6,10	6,10	6,00	6,10	6,00	6,00	6,00	6,00	6,10	6,10	6,10	6,10	6,10	6,00	6,10	6,20	6,20	
	напряж 6 кВ ТТ 1 сек. ш.	кВ	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,10	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	
	напряж 6 кВ 2Т 2 сек. ш.	кВ	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,10	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	6,20	

Директор ПО "СЭС" ГУП "ЭС" РБ Ш.Ф.Хайруллин

